

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	John Borns	Partial	Tuesday, August 15, 2017

Partial Correction

1	Misc	OK TO COVER EXTERIOR WALL SHEATHING WHEN READY AT: NW WING: 2ND FLOOR; 3RD FLOOR; 4TH FLOOR SE WING: 2ND FLOOR; 3RD FLOOR; 4TH FLOOR; [5TH FLOOR
---	------	---

All Rough Inspection - Commercial	John Borns	Not Ready	Tuesday, August 15, 2017
--	------------	-----------	--------------------------

Partial Correction

1	Misc	WALLS AND CEILING AT LINK CORRIDOR A111 OK TO COVER;
Corrective Action Required		
2	Misc	2ND FLOOR UNITS: 203; 204; 232; 233 NOT APPROVED TO COVER - FASTEN SILL PLATES PER DRAWINGS - FASTEN DOUBLE, TRIPLE AND PACKED STUDS PER DRAWINGS - INSTALL STUD SHOES WHERE REQUIRED FOR PLUMBING BORES - INSTALL BOCA PLATES WHERE REQUIRED BY IPC

Comments: