

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160939, Building Permit - Commercial
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Partial	Tuesday, August 15, 2017

Corrective Action Required

1 Misc

****INSPECTED ZONE A AND C CORRIDOR AND BATHROOMS
PRE-ROCK FOR CEILING ONLY: OK TO ROCK CEILING**

****ZONE B ABOVE-CEILING: OK TO INSTALL 1ST LAYER , EXCEPT
FOR THE COMMON AREA,**

**CEILING SPACE BELOW RATED CEILING:
-ZONE A-CORRIDOR: NEED TO FIRECAULK AROUND MEMBRANE
PENETRATIONS AND DAMPERS, COVER EXPOSED FRAMING WITH
TYPE X ROCK**

Comments: