

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20170431, Building Permit - Residential

Address: 2222 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822224 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822226 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822220 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mark Harding	Failed	Wednesday, August 16, 2017

### Corrective Action Required

1	Misc	2220 - -NORTH GARAGE WALL PLATE BOLT -FIRESTOP BATH VENT BOX OUT IN GARAGE WALL. - FIRESTOP HEAT CHASE FROM JOIST SPACE 1ST FLOOR** firestop from drop ceiling over bathroom solid block with wood. -2222- PLUMBING PROTECTION PLATES NOTCHED FLOOR JOIST OVER KITCHEN -PLUMBING PROTECTION PLATES 2ND FLOOR - STRAP CUT PLATES 2ND FLOOR AT 3" DWV. -2224 BLOCK OFF BSMT SOUTH EAST CORNER FROM 1ST FLOOR. NOTCHED FLOOR JOIST FOR AC LINE SOUTH SIDE. NOTCHED JOIST OVER KITCHEN 2226 CUT OFF UPPER GROUND AND REBAR AND INSTALL IN THE BSMT. FIRESTOP INCOMPLETE.
---	------	---

INSTALL PLUMBING PROTECTION PLATES ALL UNITS WHERE REQUIRED.

items incomplete at time of inspection 8/16

**Comments:**