

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161760, Building Permit - Commercial
Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	John Borns	Partial	Wednesday, August 16, 2017

Partial Correction
1 Misc

POOL SHELL RE-BAR FOUND TO BE BONDED AT PERIMETER WITH LEADS TO ABOVE POUR ELEVATION. **JUMPER FROM SHELL STEEL TO OUTDOOR LOUNGE SLAB RE-BAR MAT.**

Comments: