

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20171228, Building Permit - Residential

Address: 617 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081619 NW LILAC PL, LEES SUMMIT, MO
64081615 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	John Borns	Passed	Wednesday, August 16, 2017
Water Service Inspection - Residential	John Borns	Passed	Wednesday, August 16, 2017

**Comments: OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING.
NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.
WATER METER WELLS SET FOR: NORTH METER TO FEED IRRIGATION SYSTEM; SOUTH METER TO FEED
THREE TRI-LEX UNITS. 10' COPPER EXTENDED FROM EACH.**