**LEE'S SUMMIT** M I S S O U R I

## PUBLIC WORKS ENGINEERING DIVISION

## **Inspection Summary**

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item: Inspection:	Inspector:	Outcome:	Date:
PW-Sanitary Sewer Construction Inspection	Brice Lawson	Partial	Wednesday, August 16, 2017
Informational			
1 Brice Lawson 08/	′16/2017 4:30 PM		
Podford installed	approx 125' of 15" SDP 2	6 from MHA 2 towards M	H A A Thoy installed

Redford installed approx.135' of 15" SDR 26 from MH A-3 towards MH A-4. They installed the wyes for lots 63 and 85. It appeared that the pipe was being properly bedded in clean gravel.

**Comments:**