

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20171326, Building Permit - Residential
Address: 1828 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Mark Harding	Failed	Thursday, August 17, 2017

Corrective Action Required

1	Misc	not holding pressure wardflex isn't bonded
		Denied - gravel from one end of Blackstone to the other . clean street and recall.

Erosion Control	Mark Harding	Failed	Thursday, August 17, 2017
------------------------	--------------	--------	---------------------------

Corrective Action Required

1	Misc	clean entire street. from Benziger to stoneybrook.
---	------	--

Comments: