

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20171149, Building Permit - Commercial  
Address: 1710 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Passed	Thursday, August 17, 2017

<b>Above Ceiling Inspection</b>	John Borns	Partial	Thursday, August 17, 2017
---------------------------------	------------	---------	---------------------------

Partial Correction  
1 Misc

OK TO COVER WHEN READY GWB CEILING / SOFFIT FRAMING +  
ABOVE-CEILING SYSTEMS @: **SOFFITS AT SALES AREA;**

**Comments: OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING. MAIN DRAIN COMPLETE TO CONNECTION TO EXISTING BUILDING DRAIN LINE AT REAR. NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.**