

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20171556, Building Permit - Residential
Address: 1721 NE PARKWOOD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Khanh Nguyen	Passed	Thursday, August 17, 2017

Gas Service Inspection - Residential	Khanh Nguyen	Passed	Thursday, August 17, 2017
---	--------------	--------	---------------------------

All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, August 17, 2017
---	--------------	--------	---------------------------

Corrective Action Required

1 Misc

FRAMING:

- FIREBLOCK THE B-VENT CHASE FROM ROOF
- STRAP HEADER AND NAIL SHEATHING PER CS-PF DETAIL AT FRONT BED AND REAR DINING WALLS
- INSTALL LIB PER PLAN

ELECTRICAL:

- BOND HYDROTUB MOTOR
- SECURELY FASTEN WIRING MIN. 1.25" AWAY FROM STUD NAILING SURFACE AT MASTER TOILET
- PROTECT WIRING BEHIND REFRIGERATOR
- COMPLETE ELECTRICAL

****OK TO INSULATE**

Comments: