

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20170431, Building Permit - Residential

Address: 2222 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822224 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822226 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822220 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Failed	Thursday, August 17, 2017

Corrective Action Required

1	Misc	2220 - - FIRESTOP HEAT CHASE FROM JOIST SPACE 1ST FLOOR** firestop from drop ceiling over bathroom solid block with wood. -2222- PLUMBING PROTECTION PLATES NOTCHED FLOOR JOIST OVER KITCHEN -PLUMBING PROTECTION PLATES 2ND FLOOR -2224 NOTCHED JOIST OVER KITCHEN
---	------	--

Comments: