

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161178, Building Permit - Commercial
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Partial	Friday, August 18, 2017

Partial Correction
2 Misc

DUCT WRAP WAS COMPLETED WITHOUT INSPECTION OF FIRST LAYER. OUTER LAYER HAS BEEN PARTIALLY OPENED AT BOTTOM OF HORIZONTAL RUN TO EXPOSE FIRST LAYER.

Comments: