

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, August 18, 2017

Partial Correction

1 Misc

OK TO TAP, MUD AND FIRE-STOP 5/8" TYPE X GWB AT CEILING
AND WALLS AT: LINK CORRIDOR A111 SOUTH 36' +
"B"-TO-COMMONS LINK;

Partial Correction

2 Misc

**OK TO TAPE, MUD, SIRE-STOP AND COVER PRE-ROCK AT
SHOWERS/TUBS AT: 203; 204; 232; 233;**

Comments: