

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20162298, Building Permit - Residential
Address: 3913 NE TROON DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, August 18, 2017

Corrective Action Required

1	Misc	-FINAL GRADE, SOD, SPLASHBLOCKS -RAISE WATER METER TO FINAL GRADE LEVEL. -INSTALL SPARK RING FOR FLOOR RECEPTACLE -PROVIDE ACCESS TO HYDROTUYB MOTOR AND RECEPTACLE. ACCESS PANEL STUCK -INSTALL BREAKER LOCKS FOR OVEN AND COOKTOP -LOCATE AND MAKE ACCESSIBLE UFER GROUNDING CONNECTION -ONE UNLABELED BREAKER -INSTALL AFCI BREAKER FOR BASEMENT BED CIRCUIT
---	------	--

Comments: