LEE'S SUMMIT

## PUBLIC WORKS ENGINEERING DIVISION

## **Inspection Summary**

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item: Inspection:	Inspector:	Outcome:	Date:
PW-Sanitary Sewer Construction Inspection	Brice Lawson	Partial	Friday, August 18, 2017
Informational			
1 Brice Lawson 08/18/2017 11:56 AM			
Redford installed the MH frame and lid and wrapped the frame on MH A-2 and MH A-3.			
PW-Sanitary Sewer - Invert	Brice Lawson	Partial	Friday, August 18, 2017
Informational			
1 Brice Lawson 08/18/2017 12:02 PM			
Redford installed the inverts in Manholes: A-1, A-2, A-3 and U-1. They appear to be smooth troweled and built up on the sides 1/2 the diameter of the pipe.			

## Comments:

220 SE Green Street | Lee's Summit, MO 64063 | 816.969.1800 | 816.969.1810 Fax | cityofLS.net/Development