

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161758, Building Permit - Commercial
Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Friday, August 18, 2017

Underground Electrical Inspection - Commercial	John Borns	Partial	Friday, August 18, 2017
---	------------	---------	-------------------------

Partial Correction
3 Misc

OK TO COVER WHEN READY TRENCHED SITE LIGHTING CONDUIT
AT: BETWEEN POINTS #1 - #3; NW 25' FROM #4;

Comments: