

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20170094, Building Permit - Residential  
Address: 400 SE WEISS CIR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mike Copeland	Failed	Monday, August 21, 2017

### Corrective Action Required

1 Misc

**\*\*INSTALL EROSION CONTROL AT THE REAR OF PROPERTY.  
DISCHARGING INTO THE CREEK. PROTECT THE STREET  
FRONT.\*\***

-LOWER WATER METER TO FINISH GRADE. MAKE SURE METER IS  
14"-18" FROM THE LID.

-INSTALL FINAL GRADE, SOD, DOWNSPOUTS, SPLASHBLOCKS.

-PROTECT I JOISTS IN UNFINISHED BASEMENT.

### Comments: