

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20170794, Public Works Infrastructure Permit - Residential
Eagle Creek 15th Plat

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| Inspection: | Inspector: | Outcome: | Date: |
|--|-------------------|-----------------|--------------------------------|
| PW-Erosion Sediment Control (ESC) Inspection | Tom Chandler | Failed | Tuesday, August 22, 2017 |

Informational

- 1 Tom Chandler 08/22/2017 10:22 AM ESC devices are not in place along west side of Storm sewer line 2. There needs to be additional ESC devices along the creek in that area.

Comments:
