

**PUBLIC WORKS ENGINEERING DIVISION**

# Inspection Summary

Permit #: PRPWFC20172147, Public Works Infrastructure Permit - Commercial  
 B&J Peerless Addition  
 Address: 2301 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
PW-Erosion Sediment Control (ESC) Inspection	John DiMauro	Failed	Tuesday, August 22, 2017

Informational

1 John DiMauro 07/25/2017 11:31 AM  
 The silt fence is installed and intact according to the plans.

Informational

2 John DiMauro 07/27/2017 3:42 PM  
 The sediment fence is intact. No debris washing out.

Informational

3 John DiMauro 08/07/2017 3:36 PM  
 The sediment fence is intact. No debris washing out.

Informational

4 John DiMauro 08/08/2017 3:24 PM  
 The sediment fence is intact. No debris washing out.

Corrective Action Required

5 John DiMauro 08/22/2017 10:28 AM  
 There are problems with the erosion control devices on your site. There is a section of the sediment fence that has failed due to the rain event. This fence needs to be fixed and corrected.

PW-Site Visit	John DiMauro	Partial	Tuesday, August 22, 2017
---------------	--------------	---------	--------------------------

Informational

1 John DiMauro 07/24/2017 3:36 PM

No activity today.

Informational

2 John DiMauro 07/25/2017 11:32 AM

Crew on site starting the demo of the existing concrete areas to be reconstructed.

Informational

3 John DiMauro 07/27/2017 3:44 PM

Trench and grading construction.

Informational

4 John DiMauro 07/28/2017 10:23 AM

Crews on site working on the building construction.

Informational

5 John DiMauro 07/31/2017 3:40 PM

Crews on site working on the building construction.

Informational

6 John DiMauro 08/01/2017 2:04 PM

Crews on site working on the building construction.

Informational

7 John DiMauro 08/02/2017 2:53 PM

Crews are on site installing the storm pipe.

Informational

8 John DiMauro 08/03/2017 3:03 PM

Crews working on storm pipe.

Informational

9 John DiMauro 08/07/2017 3:35 PM

Crews on site working on the building construction.

Informational

10 John DiMauro 08/08/2017 3:23 PM

Crews on site working on the building construction.

Informational

11 John DiMauro 08/09/2017 3:45 PM

Crews on site working on the building construction.

Informational

12 John DiMauro 08/22/2017 10:30 AM

No activity.

**Comments:**

---