

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20171531, Building Permit - Commercial
Address: 3500 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mike Copeland	Partial	Tuesday, August 22, 2017

Corrective Action Required

1	Misc	INSTALL CLEANOUTS FOR EAST END OF NORTH CHAIR GROUP AND FOR LOOP VENT. WILL CHECK LATER. OKAY TO COVER.
---	------	---

Comments: