

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,
MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Tuesday, August 22, 2017

Partial Correction

1	Misc	OK TO TAP, MUD AND FIRE-STOP 5/8" TYPE X GWB AT CEILING AND WALLS AT: LINK CORRIDOR A111 SOUTH 36' + "B"-TO-COMMONS LINK;
---	------	---

Partial Correction

2	Misc	OK TO TAPE, MUD, FIRE-STOP AND COVER PRE-ROCK AT SHOWERS/TUBS AT: 203; 204; 232; 233;
---	------	---

Partial Correction

3	Misc	OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB ABOVE CEILING AT BACKSIDE OF STAIRWELL AT: 203; 204; 232;
---	------	---

All Rough Inspection - Commercial	John Borns	Partial	Tuesday, August 22, 2017
--	------------	---------	--------------------------

Partial Correction

1	Misc	OK TO COVER CORRIDOR WALLS AND CEILINGS AT: LINK CORRIDOR A111; NW CORRIDOR; CORR 305;
---	------	---

Partial Correction

2	Misc	OK TO COVER WHEN READY WALL AND CEILING FRAMING + SYSTEMS TO BE ENCLOSED AT: 2ND FLOOR UNITS/SPACES: 203; 204; 232; 233;
---	------	---

[3RD FLOOR UNITS/SPACES: UNITS 303, 304, 332, 333;

OK FOR 5/8" TYPE X GWB AT WALL ABOVE CEILING AT BACKSIDE OF STAIRWELL AT 303, 304, 332;

Comments: