

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20170985, Building Permit - Commercial  
Address: 1706 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection - Commercial</b>	John Borns	Passed	Wednesday, August 23, 2017
<b>In-wall Inspection</b>	John Borns	Partial	Wednesday, August 23, 2017

Partial Correction  
1      Misc      OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING  
+ IN-WALL SYSTEMS AT FOLLOWING SPACES: **105; 107; 108; 111;**

**Comments: NO ISSUES FOUND ON UNDER-SLAB ELECTRICAL CONDUIT & BOXES MATERIAL & WORKMANSHIP AT 101 EAST. G.C. AND E.C. TO ENSURE LAYOUT IS CORRECT. OK TO COVER WHEN READY**