

Temporary Certificate of Occupancy

Permit #: PRRES20170094
Address: 400 SE WEISS CIR, LEES SUMMIT, MO 64063
Inspected On: Wednesday, August 23, 2017
Inspected By: Dale Carter
Expiration Date: 9/28/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Dale Carter	Temporary C of O	Wednesday, August 23, 2017

Corrective Action Required:

- 1 Misc -LOWER WATER METER TO FINISH GRADE. MAKE SURE METER IS 14"-18" FROM THE LID.
-INSTALL FINAL GRADE, SOD, DOWNSPOUTS, SPLASHBLOCKS.