

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20171899, Building Permit - Commercial
Address: 1706 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	John Borns	Partial	Wednesday, August 23, 2017

Partial Correction
1 Misc

AT PIER AT (7.1) FOUR ANCHOR BOLT HOLES WERE DRILLED,
BRUSHED AND BLOWN; THEN BOLTS WERE SET IN EPOXY. NO
ISSUES NOTED.

Comments: