

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160939, Building Permit - Commercial  
Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Khanh Nguyen	Partial	Wednesday, August 23, 2017

Partial Correction

1 Misc

UNDERGROUND ELECTRICAL OK BELOW:  
-UE FOR EXTERIOR LIGHTS AND POWER

LIGHT POLES PIERS:  
-6 LP PIERS OK TO POUR

LP UG CIRCUIT-PROVIDE MIN 18" OF BURIAL DEPTH

<b>Above Ceiling Inspection</b>	Khanh Nguyen	Partial	Wednesday, August 23, 2017
---------------------------------	--------------	---------	----------------------------

Corrective Action Required

1 Misc

**\*\*INSPECTED ZONE A AND C CORRIDOR AND BATHROOMS  
PRE-ROCK FOR CEILING ONLY: OK TO ROCK CEILING**

**\*\*ZONE B ABOVE-CEILING: OK TO INSTALL 1ST LAYER , EXCEPT  
FOR THE COMMON AREA,**

CEILING SPACE BELOW RATED CEILING:  
-ZONE A&C-CORRIDOR: NEED TO FIRECAULK AROUND  
MEMBRANE PENETRATIONS AND DAMPERS, COVER EXPOSED  
FRAMING WITH TYPE X ROCK AT TOP

**Comments:**

