

Temporary Certificate of Occupancy

Permit #: PRRES20163237
Address: 1340 NE BRANDYWINE RD, LEES SUMMIT, MO 64064
Inspected On: Thursday, August 24, 2017
Inspected By: Khanh Nguyen
Expiration Date: 9/25/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Thursday, August 24, 2017

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | 1. splashblocks, sod, etc.
2. Seal exterior penetrations.
3. Secure guardrail post at northwest side of deck. |
|---|------|---|