

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial
Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Friday, August 25, 2017

Partial Correction

1 Misc

ELEVATOR LID: OK TO APPLY 1ST LAYER 5/8" TYPE X GWB;

Partial Correction

2 Misc

OK TO COVER WHEN READY **CEILING AND WALL FRAMING & ENCLOSED SYSTEMS AT LINK CORRIDOR 103**

Comments: