

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20172433, Building Permit - Residential
Address: 4709 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Khanh Nguyen	Passed	Friday, August 25, 2017

Erosion Control	Khanh Nguyen	Failed	Friday, August 25, 2017
------------------------	--------------	--------	-------------------------

Corrective Action Required

1	DCM1 Erosion Control	EROSION CONTROL REQUIRED. A GRAVEL FILTER SHALL BE PROVIDED AT DRIVEWAY ENTRANCE. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.
---	----------------------	--

Comments: