

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171814, Building Permit - Residential
Address: 4713 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| | | | |
|---|--------------|----------|-------------------------|
| Inspection: | Inspector: | Outcome: | Date: |
| All Rough Inspection - Residential | Khanh Nguyen | Failed | Monday, August 28, 2017 |

Corrective Action Required

| | | |
|---|------|--|
| 1 | Misc | -ANCHOR ALL SILL PLATES WITHIN 12" OF BREAKS IN BASEMENT **AT EXTERIOR DOOR |
|---|------|--|

Comments: