

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20163205, Building Permit - Residential
Address: 4832 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Monday, August 28, 2017

Corrective Action Required

1	Misc	-FINAL GRADE, SOD, SPLASHBLOCKS -EXPOSE SEWER TRACER BOX -ESTABLISH GAS SERVICE -SEAL EXTERIOR WALL PENETRATIONS, ABOVE AC DISCONNECT AND METER, ETC -COOKTOP: INSTALL FMC CONNECTOR AT BOX AND SECURE FMC WITHIN 12" OF BOX AND COOKTOP -RECEPTACLE WITHIN SIX FT OF THE WET BAR SINK MUST BE GFCI-PROTECTED -WHERE'S THE UFER GROUNDING CONNECTION? -REMOVE ALL SMOKE ALARM COVERS
---	------	--

Comments: