

Temporary Certificate of Occupancy

Permit #: PRRES20163205
Address: 4832 NE JAMESTOWN DR, LEES SUMMIT, MO 64064
Inspected On: Monday, August 28, 2017
Inspected By: Khanh Nguyen
Expiration Date: 9/28/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Monday, August 28, 2017

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | -FINAL GRADE, SOD, SPLASHBLOCKS
-EXPOSE SEWER TRACER BOX
-ESTABLISH GAS SERVICE
-SEAL EXTERIOR WALL PENETRATIONS, ABOVE AC DISCONNECT AND METER, ETC
-COOKTOP: INSTALL FMC CONNECTOR AT BOX AND SECURE FMC WITHIN 12" OF BOX AND COOKTOP
-RECEPTACLE WITHIN SIX FT OF THE WET BAR SINK MUST BE GFCI-PROTECTED
-WHERE'S THE UFER GROUNDING CONNECTION?
-REMOVE ALL SMOKE ALARM COVERS |
|---|------|---|

