

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential
Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Sanitary Sewer Construction Inspection	Brice Lawson	Partial	Monday, August 28, 2017

Informational

- 1 Brice Lawson 08/28/2017 12:55 PM
Redford installed the sanitary stubs with tracer wire for lots and 65. The tracer wire has been installed and wrapped around a post at grade. The pipes were bedded in clean rock.

They installed the wye fittings for lots 70 and 92.

DEI-Sanitary Sewer Construction Inspection	Brice Lawson	Partial	Monday, August 28, 2017
---	--------------	---------	-------------------------------

Informational

- 1 Brice Lawson 08/28/2017 9:33 AM
Redford installed the sanitary stub for lot 63. The tracer wire has been installed and attached to a board at grade. The stub has been bedded in clean rock.

Redford continues to install the 15" sanitary main between MH A-4 and A-5.

Comments: