

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161750, Building Permit - Commercial  
Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Failed	Monday, August 28, 2017
Partial Correction 1        Misc		OK TO COVER WHEN READY SHEAR WALLS AT STAIRWELLS: SOUTH STAIRWELL: LEVEL 1; NORTH STAIRWELL: LEVEL 1;	
Partial Correction 2        Misc		PRELIMINARY FRAMING INSPECTION REQUIRED CORRECTIONS POINTED-OUT AT 4TH FLOOR; 3RD FLOOR;  <b>[NOT APPROVED AT 2ND FLR; 1ST FLR; BASEMENT</b>	
Partial Correction 3        Misc		ROOF SHEATHING NAILED IN PLACE; EXTERIOR WALL SHEATHING NAILING APPROVED FULL HEIGHT	

**Comments:**