

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20161756, Building Permit - Commercial  
Address: 795 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Monday, August 28, 2017

Partial Correction  
1 Misc

RATED ASSEMBLY AT STAIRWELLS:  
OK TO COVER 5/8" TYPE X MOLD TOUGH GWB AT

NORTH STAIRWELL WALLS: 2ND LAYER AT 1ST LEVEL WELL FACE + 1ST LAYER PRE-ROCK AT JOIST SPACE AT BACKSIDE; 1ST LAYER AT 2ND LEVEL WELL FACE; 2ND LAYER AT 2ND LEVEL WELL FACE + PRE-ROCK AT JOIST SPACE AT BACKSIDE; 1ST LAYER AT 3RD LEVEL WELL FACE; PRE-ROCK AT JOIST SPACE AT BACKSIDE AT 1ST, 2ND & 3RD FLOORS; 1ST LAYER AT 4TH FLOOR; 2ND LAYER AT 3RD & 4TH FLOORS; 1ST LAYER AT WALLS & CEILING ABOVE 4TH FLOOR; 2ND LAYER AT WALLS & CEILING ABOVE 4TH FLOOR; 3RD LAYER + RC CHANNEL AT LOW AND HIGH CEILINGS ABOVE 4TH FLOOR; 4TH LAYER AT LOW AND HIGH CEILINGS ABOVE 4TH FLOOR;

SOUTH STAIRWELL WALLS: 2ND LAYER AT 1ST LEVEL WELL FACE + 1ST LAYER PRE-ROCK AT JOIST SPACE AT BACKSIDE; 1ST LAYER AT 2ND LEVEL WELL FACE; 2ND LAYER AT 2ND LEVEL WELL FACE + PRE-ROCK AT JOIST SPACE AT BACKSIDE; 1ST LAYER AT 3RD LEVEL WELL FACE + PRE-ROCK AT JOIST SPACE AT BACKSIDE; 1ST LAYER AT 4TH FLOOR; 2ND LAYER AT 3RD & 4TH FLOORS; 1ST LAYER AT WALLS & CEILING ABOVE 4TH FLOOR; 2ND LAYER AT WALLS & CEILING ABOVE 4TH FLOOR; 3RD LAYER + RC CHANNEL AT LOW AND HIGH CEILINGS ABOVE 4TH FLOOR; 4TH LAYER AT LOW AND HIGH CEILINGS ABOVE 4TH FLOOR;

Partial Correction  
2 Misc

OK TO COVER WHEN READY RATED ASSEMBLY AT ELEVATOR SHAFT:

Partial Correction 3            Misc	<p>1ST &amp; 2ND LAYERS PERIMETER PRE-ROCK AT JOIST SPACE AT 1ST, 2ND, AND 3RD FLOORS;</p> <p>5/8" TYPE X GWB AT WELL FACE: 2ND LAYER AT 4TH, 3RD, 2ND, 1ST FLOORS</p> <p>SHAFT LID: 1ST LAYER; 2ND LAYER; 3RD LAYER;</p> <p>OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB RATED CEILINGS &amp; WALLS AT: 4TH FLOOR; 3RD FLOOR INCLUDING BOTH STAIRWELLS; <b>[2ND FLOOR;</b></p>
Partial Correction 4            Misc	<p>1ST FLOOR: 1ST LAYER ;</p> <p>OK TO COVER WHEN READY 1ST LAYER 5/8" TYPE X GWB AT BACKSIDE FACE OF STAIRWELLS, ELEVATOR SHAFT AND SHEAR WALLS BOTH FACES AT: 4TH FLOOR; 3RD FLOOR; [2ND FLOOR;</p>
Partial Correction 5            Misc	<p>PENETRATIONS ABOVE GWB CEILING AT FOUR LAUNDRY ROOMS AT 4TH FLOOR OK TO COVER</p>

**Comments:**