



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20161058	Date:	August 29, 2017
Project Title:	WATER UTILITIES FACILITY (HAMBLEN RD)	Applicant:	
Location:	1200 SE HAMBLEN RD, LEES SUMMIT, MO 64081	YATES ELECTRIC CO INC	1401 BURLINGTON C KANSAS CITY, MO 64116
Type of Work:		Primary:	(816) 421-8343
Occupancy Group:	S-1		
Description:	NEW WATER UTILITIES FACILITY		
Construction Type:	Type IIB (Unprotected)		
Map Page:	195R		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Acceptance testing of the system will be required prior to the final occupancy inspection. To schedule testing contact the fire department. 816-969-1300

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.