

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161758, Building Permit - Commercial

Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	John Borns	Failed	Tuesday, August 29, 2017

Corrective Action Required

1	Misc	LSCO 7-608: GAS PIPING TEST PRESSURE DECREASED DURING MONITORING PERIOD. CORRECT AND PRESSURIZE PIPING SYSTEM TO HOLD STEADY AT MINIMUM 10 PSI
---	------	--

Comments: