

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT,  
MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	Partial	Tuesday, August 29, 2017

Partial Correction

1	Misc	OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB AT CEILING AND WALLS AT: LINK CORRIDOR A111 SOUTH 36' + "B"-TO-COMMONS LINK; CORR 205 WALLS + LID; <b>[CORR A-305 LID &amp; WALLS;</b>
---	------	--

UNITS **[203; 204; 232; 233;**

Partial Correction

2	Misc	OK TO TAPE, MUD, FIRE-STOP AND COVER PRE-ROCK AT SHOWERS/TUBS AT: 203; 204; 232; 233; 303; 304; 332; 333; 403; 404; 432; 433;
---	------	---

Partial Correction

3	Misc	OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB ABOVE CEILING AT BACKSIDE OF STAIRWELLS AT: 203; 204; 232; 303; 304; 332; 333; 403; 404; 432; 433; <b>[303; 304; 332;</b>
---	------	---

**Comments:**