

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171814, Building Permit - Residential

Address: 4713 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection - Residential	Khanh Nguyen	Partial	Wednesday, August 30, 2017

Sewer Service Inspection - Residential	Khanh Nguyen	Partial	Wednesday, August 30, 2017
---	--------------	---------	----------------------------

Corrective Action Required

1	Misc	-CONNECT SEWER TRACER WIRE WITH SPLIT BOLT AND RUN TO HOUSE
---	------	---

Comments: