

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170812, Building Permit - Residential

Address: 1622 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Dale Carter	Passed	Thursday, August 31, 2017
Sewer Service Inspection - Residential	Dale Carter	Passed	Thursday, August 31, 2017
Erosion Control	Mike Copeland	Failed	Thursday, August 31, 2017

Corrective Action Required

1	Misc	-EROSION CONTROL IN THE FRONT NEEDS TO EXTEND TO THE EAST WHERE AREA WAS DISTURBED FROM CONSTRUCTION FROM THIS LOT. -REAR OF THE LOT IS DISCHARGING INTO THE SECONDARY MEANS OF ESC AND NEEDS TO BE PROTECTED.
---	------	---

Comments: Met with Gordon on-site, got on conference call with Superintendent. Discussed corrections which will be completed by tomorrow. Including removal of silt at rear and re-building of rock-check; Repair & replacement of silt fence at rear; Installation of silt-fence along east property line.