Development Services Department

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

oer 01, 2017		
/B AT CEILING +		
CORR A-305 LID		
JNITS 203; 204; 232; 233;		
OK TO TAPE, MUD, AND FIRE-STOP PRE-ROCK AT SHOWERS/TUBS AT: 203; 204; 232; 233; 303; 304; 332; 333; 403; 404; 432; 433; 201; 234; 301; 334; 401; 434; [201; 234;		
) TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB ABOVE NG AT BACKSIDE OF STAIRWELLS AT: 203; 204; 232; 303;		
+, 232, 303,		
oer 01, 2017		
OK TO COVER CORRIDOR WALLS AND CEILINGS AT: LINK CORRIDOR A111; NW CORRIDOR; CORR 305; CORR LVL 4;		
OK TO COVER WHEN READY WALL AND CEILING FRAMING + SYSTEMS TO BE ENCLOSED AT: 2ND FLOOR UNITS/SPACES: 203; 204; 232; 233;		

3RD FLOOR UNITS/SPACES: UNITS 303, 304, 332, 333;

4TH FLOOR UNITS/SPACES: 403; 404; 432; 433;

OK FOR 5/8" TYPE X GWB AT WALL ABOVE CEILING AT BACKSIDE OF STAIRWELL AT 303, 304, 332;

Partial Correction 3 Misc

FRAMING & ENCLOSED SYSTEMS OK TO COVER AT SHOWER/TUB PRE-ROCK LOCATIONS AT: 201; 301; 401; 234; 334; 434; [217; 218; 221; 222; 225; 226; 227; 228; **[217; 218;**

Comments: