

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial

Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, September 01, 2017
Partial Correction 4 Misc		OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLY AT LID OF ELEVATOR SHAFT: FRAMING AND SHAFT LINER BOARD;	
All Rough Inspection - Commercial	John Borns	Partial	Friday, September 01, 2017
Partial Correction 3 Misc		OK TO COVER WHEN READY FRAMING AND SYSTEMS TO BE CONCEALED AT SOFFITS AT ELEVATOR LOBBIES	
Miscellaneous Inspection	John Borns	Partial	Friday, September 01, 2017
Partial Correction 1 Misc		PRE-FINAL INSPECTION/TEST OF REFRIGERATOR AND DISHWASHER ELECTRICAL RECEPTACLES AT LOCATIONS: 2ND FLOOR; 3RD FLOOR;	
		OK TO SET AND PLUG IN APPLIANCES WHEN READY.	

Comments: