

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170784, Building Permit - Commercial

Address: 3621 NE AKIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, September 05, 2017

Corrective Action Required

1	Misc	UNDERSLAB PLUMBING OK, EXCEPT THAT THE TRENCH IS ADJACENT TO SEVERAL COLUMN PADS THAT REQUIRES ENGINEER ADDRESS OR OK
---	------	---

Comments: