

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170130, Building Permit - Residential

Address: 404 SE WEISS CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Wednesday, September 06, 2017

Corrective Action Required

1	Misc	-INSTALL SOD, SPLASHBLOCKS -VEGETATION TO THE LOT TO THE SOUTH SHOULD BE ESTABLISHED, EROSION CONTROL SHALL BE IN PLACE FOR TEMP C OF O
---	------	--

Comments: