

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial

Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Wednesday, September 06, 2017
Partial Correction 1 Misc	OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLY AT LID OF ELEVATOR SHAFT: FRAMING AND SHAFT LINER BOARD; 1ST LAYER 5/8" TYPE X GWB;		

Comments: