

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161180, Building Permit - Commercial

Address: 501 NW SHAMROCK AVE, LEES SUMMIT, MO 64081521 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	John Borns	Partial	Wednesday, September 06, 2017
Partial Correction 1 Misc		TRENCHED FEEDER PIPE FROM SITE DISTRIBUTION LINE TO BLDG "A" OK TO COVER WHEN READY. PRESSURE TEST HALD STEADY AT >100 PSI FOR > 20 MINUTES. NO ISSUES ON VISUAL INSPECTION.	
Corrective Action Required 2 Misc		INTERIOR GAS PIPING PRESSURE TEST: GAUGE RANGE EXCEEDS 5X 15 PSI TEST PRESSURE	
Rated Assembly Inspection	John Borns	Partial	Wednesday, September 06, 2017
Partial Correction 1 Misc		OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB AT CEILING AND WALLS AT: LINK CORRIDOR A111 SOUTH 36' + "B"-TO-COMMONS LINK; CORR 205 WALLS + LID; CORR A-305 LID & WALLS; CORR 405;	
		UNITS 203; 204; 232; 233;	
Partial Correction 2 Misc		OK TO TAPE, MUD, AND FIRE-STOP PRE-ROCK AT SHOWERS/TUBS AT: 203; 204; 232; 233; 303; 304; 332; 333; 403; 404; 432; 433; 201; 234; 301; 334; 401; 434; 201; 234; [217; 218; 221; 222; 225; 226; 227; 228;	
Partial Correction 3 Misc		OK TO TAPE, MUD AND FIRE-STOP 5/8" TYPE X GWB ABOVE CEILING AT BACKSIDE OF STAIRWELLS AT: 203; 204; 232; 303;	

304; 332; 333; 403; 404; 432; 433; 303; 304; 332;

All Rough Inspection - Commercial	John Borns	Partial	Wednesday, September 06, 2017
--	------------	---------	-------------------------------

Partial Correction

1 Misc

OK TO COVER CORRIDOR WALLS AND CEILINGS AT: LINK CORRIDOR A111; NW CORRIDOR; CORR 305; CORR LVL 4;

Partial Correction

2 Misc

OK TO COVER WHEN READY WALL AND CEILING FRAMING + SYSTEMS TO BE ENCLOSED AT:
2ND FLOOR UNITS/SPACES: 203; 204; 232; 233; **[NORTH WALL AT 216;**

3RD FLOOR UNITS/SPACES: UNITS 303, 304, 332, 333;

4TH FLOOR UNITS/SPACES: 403; 404; 432; 433;

OK FOR 5/8" TYPE X GWB AT WALL ABOVE CEILING AT BACKSIDE OF STAIRWELL AT 303, 304, 332;

Partial Correction

3 Misc

FRAMING & ENCLOSED SYSTEMS OK TO COVER AT SHOWER/TUB PRE-ROCK LOCATIONS AT: 201; 301; 401; 234; 334; 434; [217; 218; 221; 222; 225; 226; 227; 228; [217; 218;

Comments: