

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFR20171746, Public Works Infrastructure Permit - Residential  
Manor at Stoney Creek 2nd - street, storm, sewer and water

Address:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

<b>Inspection:</b>	<b>Inspector:</b>	<b>Outcome:</b>	<b>Date:</b>
DEI - Sanitary - Material Verification	Brice Lawson	Failed	Wednesday, September 06, 2017

Corrective Action Required

- 1 Brice Lawson 09/06/2017 12:35 PM  
The concrete flat top lid for manhole D-1 is not equipped with a cast in place manhole ring and cover.

A detail for this flat top lid is shown on the details page for these plans.

Replace this lid to meet spec.

**Comments:**