

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20171401, Public Works Infrastructure Permit - Commercial
Ward Rd Expansion
Address: 700 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Site Visit	Steve Robbins	Partial	Wednesday, September 06, 2017

Informational

- 1 Contractor wanted to know if they needed a proofroll for the fly-ash. I called Jerry and he said yes, and they needed the compaction test results of 95%. He called Jerry and he is going to come watch the proofroll when they get a truck in.

Informational

- 2 Yesterday while Jerry Smith was out they were installing the mo-type 5 and compacting it in.

Comments: