

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20160939, Building Permit - Commercial

Address: 3320 NE WILSHIRE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:

Inspector:

Outcome:

Date:

**Gas Piping Inspection -**  
**Commercial**

Khanh Nguyen

Passed

Wednesday, September 06,  
2017

### Comments:

UNDERGROUND GAS LINE TO THE GENERATOR TESTED OK