

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20161750, Building Permit - Commercial

Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|  |            |          |                              |
|--|------------|----------|------------------------------|
| Inspection:                              | Inspector: | Outcome: | Date:                        |
| <b>All Rough Inspection - Commercial</b> | John Borns | Partial  | Thursday, September 07, 2017 |

Partial Correction

1 Misc

OK TO INSTALL PRE-ROCK INSULATION AND GWB WHEN READY  
AT SHOWER PRE-ROCK AREAS AT:

4TH FLOOR UNITS;

**3RD FLOOR UNITS;**

**NOTE: SHOWER WATER PIPING TO BE STRAPPED TO FRAMING;  
SHOWER VALVES TO BE SECURED PER MANUFACTURER  
INSTRUCTIONS**

Comments: