

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161177, Building Permit - Commercial

Address: 500 NW MOORE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, September 07, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY COMPONENTS OF RATED ASSEMBLY AT LID OF ELEVATOR SHAFT:

FRAMING AND SHAFT LINER BOARD; 1ST LAYER 5/8" TYPE X
GWB; **2ND LAYER 5/8" TYPE X GWB;**

Partial Correction

2 Misc

OK TO TAPE, MUD AND FIRE-STOP WHEN READY 5/8" TYPE X
GWB AT: **WALLS AT LINK 101/104**

Comments: