

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172339, Building Permit - Commercial

Address: 300 SW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Thursday, September 07, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY LIGHT-GAUGE STEEL FRAMING +
ENCLOSED M/E/P SYSTEMS AT: **FALSE WALL AT PERIMETER
EXCEPT SOUTH WALL PARTIAL PENDING
CREATION/MODIFICATION OF OPENINGS; EAST DEMISING WALL
EXCEPT NORTH 10' NOT YET FRAMED;**

Comments: